Durocrete Engineering Services Pvt.Ltd.
PAP-D122/125,TTC Industrial Area,Behind Jai Mata Di Weighbridge,
Turbhe,Navi Mumbai-400705.
Tel No: +91-9850500013,022-27622353
Email: infomumbai@durocrete.com
An ISO/IEC 17025:2005 NABL Accredited Laboratory

DUROCRETE
Test with the Best

Website : www.durocrete.com

Test Report

Chemical Admixture

Authentication Code : 02 **Route : R7**

Customer name	: ASHTECH PRODUCT PRIVATE LIMITED	Date of Issue	: 11-Apr-2018
Office address	: 623, Arenja Corner, Plot No-71, Sector-17, Vashi, Navi Mumbai	**Record No.**	**: OT - 614/1-1-R1**
		Sample Ref No.	**: OT - 4765**
Site name	: ASHTECH PRODUCT PRIVATE LIMITED	Bill No	: 201819MUM42
Description	: Greencon IWC Batch No-LB 0303 M.F.D-March 2018	Date of receipt	: 29-Mar-2018
Supplier name	: --	Date of testing	: 31-Mar-2018
Contact Details	: Mr. Madan Chalgeri - 8097145894		

OBSERVATIONS & CALCULATIONS :

Sr no.	Name of Test	Unit	Test Result
1	pH Value	----	7.75
2	Relative Density	----	1.10
3	Solid Content	%	19.4
4	Ash Content	%	4.69
5	Chloride Content	%	BDL

References :

1) IS 9103: Specification for Concrete Admixtures

Remarks :

1) BDL-Below detection limit. (0.05 %)
2) This report supersedes OT - 614/1-1 report dated 06/04/2018

Notes :

1) The test reports and results relate to the perticular specimen/sample(s) of the material as delivered/received and tested in the laboratory.
2) Any test report shall not be reproduced except in full,without the written permission from Durocrete.
3) Any alteration/change in the originally printed and issued report, would render this report as INVALID.

This report can be authenticated on our website www.durocrete.com

Authorized Signatory

P R Kulkarni

Prakash Kulkarni
(V.P. Operations)
11/04/18

Checked by : Neeta Nivangune

--End of Report--